

BPA Commercial Air Source Heat Pump measure

Requirements for ASHP UPGRADE REBATE

Mode: **HEATING**

Equipment Size (Cooling Capacity; BTU/H)	Rating Condition	Efficiency Requirement
<65,000	Split-System	8.1 HSPF2 or 9.6 HSPF
	Single Package	7.0 HSPF2 OR 8.3 HSPF
≥65,000 and <135,000	47°F db/43°F wb Outdoor Air	3.5 COP
≥135,000 and <240,000	47°F db/43°F wb Outdoor Air	3.4 COP
≥240,000	47°F db/43°F wb Outdoor Air	3.4 COP